

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3550-0075:173 Page 1 of 1

**CATEGORY:** Door Closers/Holders

**LISTEE:** Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653  
Contact: \*Brian Reynolds (203) 484-1200 Fax (203) 484-7309

**DESIGN:** Models FM980-24, FM980-120, FM996-24, FM996-120, FM998-24 and FM998-120.  
Electromagnetic. Refer to listee's data sheets for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an electromagnetic door holder for use on fire-rated doors when installed in conjunction with separately listed smoke detection devices approved for releasing device service.

**XLF:** 3550-0047:001

\*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 14, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager